

**IOWA DEPARTMENT OF NATURAL RESOURCES
NPDS REPORTING SYSTEM - DISCHARGE MONITORING REPORT
FACILITY INFORMATION**

This form is valid 4/1/2015 to 3/31/2020

Facility Name: SIOUX CITY, CITY OF STP

Permit #: 9778001

Month/Year: 10 2017

Outfall #(s): 001 - DISCHARGE FROM AN ACTIVATED SLUDGE WASTEWATER TREATMENT PLANT.


Operator Name: Mark Simms on behalf of Jim Maynes

Certification #: 5129 on behalf of 6232

Phone #: 712-279-6113

Lab Cert. #: 323

Comments: Jim Maynes, (#6232) was operator-in-charge 10/1/17-11/9/17, left employ 11/9/17. Seaboard Triumph Foods obtained 6,800 gallons of anaerobic digester sludge on November 1, 2017, to be used a seed sludge for their pretreatment facility. AB4 was offline 10/1-10/5, brought online afternoon of 10/5/17, no data available until 7-3 shift 10/6/17. E. Coli Geo Mean = 27.9#/100 mL. Extra TCR samples on 10/12 showed an effl TCR of 1.02. It is unclear if the former Supt. notified DNR.
**Include Comments longer than 1000 characters in email*

Signature:  on behalf of Jim Maynes

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for known violations.